



Product Service

Attestation of Conformity

No. N8 15 01 11675 009

Holder of Certificate: **Meltem Lüftungsgeräte
GmbH & Co. KG**

Am Hartholz 4
82239 Alling
GERMANY


Product: **Fans
Ventilation appliance**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 028-713038279



Date, 2015-01-16


(Thomas Kokorsch)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Attestation of Conformity
No. N8 15 01 11675 009

Model(s): **Type: VARIO II**
Models: V-II-30; V-II-60; V-II-100;
V-II-30/60; V-II-30/100

Parameters:

Rated voltage:	230 V~	
Rated frequency:	50 Hz	
 Rated power:		
	Vario V-II-30:	6 W
	Vario V-II-60:	17 W
	Vario V-II-100:	28 W
	Vario V-II-30/60:	6/17 W
	Vario V-II-30/100:	6/28 W
 Protection class:	II	
Degree of protection:	IPX5	

Remark:
The fans are available to built in
following frame types: Vario U, Vario UK,
Vario UB, Vario UBK, Vario U-H, Vario UK-H,
Vario UBK-H, Vario A und Vario AK.

Tested according to: EN 60335-2-80/A2:2009
EN 60335-1:2012
ZEK 01.4-08