



Product Service

CERTIFICATE

No. B 14 04 11675 008

Holder of Certificate: Meltem Lüftungsgeräte
GmbH & Co. KG

Am Hartholz 4
82239 Alling
GERMANY

Certification Mark:



Product: Fans
Ventilation appliance

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 028-713038279-000

Date, 2014-04-14

(Josef Wörl)



Page 1 of 2



Product Service

CERTIFICATE
No. B 14 04 11675 008

Model(s): **Type: VARIO II**
Models: V-II-30; V-II-60; V-II-100;
V-II-30/60; V-II-30/100

Parameters:

Rated voltage:	230 V~	
Rated frequency:	50 Hz	
Rated power:	Vario V-II-30:	6 W
	Vario V-II-60:	17 W
	Vario V-II-100:	28 W
	Vario V-II-30/60:	6/17 W
	Vario V-II-30/100:	6/28 W
Protection class:	II	
Degree of protection:	IPX5	

Remark:
 The fans are available to built in
 following frame types: Vario U, Vario UK,
 Vario UB, Vario UBK, Vario U-H, Vario UK-H,
 Vario UBK-H, Vario A und Vario AK.

Tested according to: EN 60335-2-80/A2:2009
 EN 60335-1:2012
 ZEK 01.4-08

Production Facility(ies): 11675