

**ErP Product fiche for RVU according to EU 1254/2014  
comfort ventilation unit Meltem M-WRG-II E**

<b>supplier's name</b>	Meltem Wärmerückgewinnung GmbH & Co. KG											
<b>supplier model</b>	M-WRG-II E M-WRG-II E-T M-WRG-II E-M M-WRG-II E-S 485	M-WRG-II E-F M-WRG-II E-FC M-WRG-II E-T-F M-WRG-II E-T-FC M-WRG-II E-M-F M-WRG-II E-M-FC M-WRG-II E-S 485-F M-WRG-II E-S 485-FC			M-WRG-II E M-WRG-II E-T M-WRG-II E-M M-WRG-II E-S 485			M-WRG-II E-F M-WRG-II E-FC M-WRG-II E-T-F M-WRG-II E-T-FC M-WRG-II E-M-F M-WRG-II E-M-FC M-WRG-II E-S 485-F M-WRG-II E-S 485-FC				
	without sensors without duct connection pipe	with sensor without duct connection pipe			without sensors with channel connection pipe			with sensor with channel connection pipe				
<b>SEC [kWh/(m²a)] specific energy consumption (cold, average, warm)</b>	-59,4	-27,1	-6,1	-72,8	-37,3	-14,4	-60,6	-27,5	-6,0	-73,7	-37,7	-14,4
<b>SEC class</b>	A	B	F	A	A	E	A	B	F	A	A	E
<b>typology</b>	RVU bidirectional (BVU)			..RVU bidirectional (BVU)			..RVU bidirectional (BVU)			...RVU bidirectional (BVU)		
<b>type of drive installed</b>	variable speed			variable speed			variable speed			variable speed		
<b>type of heat recovery system</b>	recuperative			recuperative			recuperative			recuperative		
<b>thermal efficiency of heat recovery <math>\eta_s</math> [%]</b>	72,3			72,3			72,3			72,3		
<b>maximum flow rate [m³/h]</b>	100			100			100			100		
<b>max. electric power input of the fan drive [W]</b>	53			53			57			57		
<b>sound power level L<sub>WA</sub> [dB(A)]</b>	SM <sup>1</sup> /FM <sup>2</sup> : 44/43			SM <sup>1</sup> /FM <sup>2</sup> : 44/43			WI <sup>3</sup> : 38			WI <sup>3</sup> : 38		
<b>reference flow rate <math>q_5</math> [m³/h]</b>	70			70			70			70		
<b>reference pressure difference [Pa]</b>	0			0			50			50		
<b>specific power input (SPI) [W/(m³/h)]</b>	0,34			0,34			0,39			0,39		
<b>control factor and control typology</b>	1 Manual control			0,65 Local demand control			1 Manual control			0,65 Local demand control		
<b>max. internal leakage rate /</b>	Inside: 0,1			Inside: 0,1			Inside: 0,3			Inside: 0,3		
<b>max. external leakage rate [%]</b>	Outside: 1,5			Outside: 1,5			Outside: 1,5			Outside: 1,5		
<b>mixing rate [%]</b>	U1: 0,0			U1: 0,0			-			-		
<b>position, description of visual filter warning</b>	Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!			Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!			Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!			Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!		
<b>internet address</b>	www.meltem.com			www.meltem.com			www.meltem.com			www.meltem.com		
<b>airflow sensitivity to pressure variations at -20 Pa and +20 Pa [%]</b>	S1: 0,9			S1: 0,9			-			-		
<b>indoor / outdoor air tightness [m³/h]</b>	outward: 2,1 inward: 2,3			outward: 2,1 inward: 2,3			-			-		
<b>AEC annual electricity consumption [kWh/(m²a)]</b>	5,1			2,4			5,3			2,5		
<b>AHS annual heating saved (cold, average, warm) [kWh/(m²a)]</b>	76,9	39,3	17,8	83,5	42,7	19,3	78,6	40,2	18,2	84,7	43,3	19,6

<sup>1</sup> surface-mount, <sup>2</sup> flush-mount, <sup>3</sup> wall-integrated U<sup>2</sup> with duct connection Exhaust air side

**ErP Product fiche for RVU according to EU 1254/2014  
comfort ventilation unit Meltem M-WRG-II E**

<b>supplier's name</b>	Meltem Wärmerückgewinnung GmbH & Co. KG										
<b>supplier model</b>	M-WRG-II E M-WRG-II E-T M-WRG-II E-M  with external radio sensor without duct connection pipe			M-WRG-II E M-WRG-II E-T M-WRG-II E-M  with external radio sensor with channel connection pipe							
<b>SEC [kWh/(m²a)] specific energy consumption (cold, average, warm)</b>	-72,8	-37,3	-14,4	-73,7	-37,7	-14,4					
<b>SEC class</b>	A	A	E	A	A	E					
<b>typology</b>	RVU bidirectional (BVU)			..RVU bidirectional (BVU)							
<b>type of drive installed</b>	variable speed			variable speed							
<b>type of heat recovery system</b>	recuperative			recuperative							
<b>thermal efficiency of heat recovery <math>\eta_5</math> [%]</b>	72,3			72,3							
<b>maximum flow rate [m³/h]</b>	100			100							
<b>max. electric power input of the fan drive [W]</b>	53			57							
<b>sound power level LWA [dB(A)]</b>	SM <sup>1</sup> /FM <sup>2</sup> :44/43			WI <sup>3</sup> : 38							
<b>reference flow rate <math>q_5</math> [m³/h]</b>	70			70							
<b>reference pressure difference [Pa]</b>	0			50							
<b>specific power input (SPI) [W/(m³/h)]</b>	0,34			0,39							
<b>control factor and control typology</b>	0,65 Local demand control			0,65 Local demand control							
<b>max. internal leakage rate / max. external leakage rate [%]</b>	Inside: 0,1 Outside: 1,5			Inside: 0,3 Outside: 1,5							
<b>mixing rate [%]</b>	U1: 0,0			-							
<b>position, description of visual filter warning</b>	Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!			Message on the control panel, runtime-controlled filter monitoring, regular filter changes are important for the performance/energy efficiency of the device!							
<b>internet address</b>	www.meltem.com			www.meltem.com							
<b>airflow sensitivity to pressure variations at -20 Pa and +20 Pa [%]</b>	S1: 0,9			-							
<b>indoor / outdoor air tightness [m³/h]</b>	outward: 2,1 inward: 2,3			-							
<b>AEC annual electricity consumption [kWh/(m²a)]</b>	2,4			2,5							
<b>AHS annual heating saved (cold, average, warm) [kWh/(m²a)]</b>	83,5	42,7	19,3	84,7	43,3	19,6					

<sup>1</sup> surface-mount, <sup>2</sup> flush-mount, <sup>3</sup> wall-integrated U<sup>2</sup> with duct connection Exhaust air side